

A sample of the following product has been tested and is stated by Nemko to be in conformity with the applicable European standards referred below.

Product LED emergency lighting (exit sign)  
Manufacturer SPARKELEC PTY LTD  
56 Parramatta Rd Croydon NSW 2132, Sydney  
Sydney  
Australia  
Factory **CONFIDENTIAL INFORMATION WITHDRAWN**

Ratings Charging mode: Max.3 W 220-240 V 50/60 Hz;  
Emergency lighting mode: 4.8 V battery, 1 W, 10/20 lm;  
Battery supply: 800 / 1200 mAh, 4.8 V d.c. Ni-MH.  
Cl. II, IP20, ta 0 - +40 oC, Maintained, 2 / 3 hours duration  
With integral LED module, with integral LED driver.

Trade mark 

Model / Type Ref. SP-2001-xx-MHyyy series

Principal characteristics See page 2

A sample of the product was tested and found to be in conformity with

LITE	EN 60598-1:2015
	EN 60598-2-22:2014
EMF	EN 62493:2015
EMC	EN 55015:2013;A1
	EN 61547:2009
	EN 61000-3-2:2014
	EN 61000-3-3:2013

Test Report Ref. No. **CONFIDENTIAL INFORMATION WITHDRAWN**

It may therefore be presumed that the tested sample of the product is in conformity with the technical provisions of the following European Directives including the latest amendments, and with national legislation implementing these Directives:

- Low Voltage Directive 2014/35/EU
- EMC Directive 2014/30/EU

**Provided that other applicable Directive requirements are satisfied, the manufacturer (or the European authorized representative), may draw up an EC/EEA Declaration of Conformity and affix the CE-marking to each conforming product.**

Additional model(s)

Additional information

Date of issue 24-01-2017



Jiyea Gim  
Certification Department

Principal characteristics

The "xx" in the type designation can be "WH" or "BK", indicating the colour of background of exit signs, see attachment 8

xx = WH: The colour of background of exit signs is green, also the colour of plastic enclosure of luminaire is white;

xx = BK: The colour of background of exit signs is black, also the colour of plastic enclosure of luminaire is black.

The "yyy" can be 120 or 180, indicating the rated emergency duration in minute.

yyy = 120: 120 minutes;

yyy = 180: 180 minutes

Date of issue 24-01-2017



Jiyea Gim

Certification Department

**Nemko AS**

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway

TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL [info@nemko.com](mailto:info@nemko.com)

ENTERPRISE NUMBER NO974404532